
Engineering Specification



Aspirating Smoke Detector

TITANUS PRO-SENS® /net TP-4
Cold Storage Variant

TABLE OF CONTENTS

SCOPE	Page 3
1 TITANUS® Family – Introduction	Page 3
2 TITANUS PRO-SENS® /net TP-4-F – General Information	Page 3
3 Approvals	Page 4
4 Codes, Standards or Regulations	Page 4
5 System Description	Page 5
5.1 General Requirements	Page 5
5.2 Performance Requirements	Page 6
5.3 System Design Requirements	Page 6
5.4 Application Specific Requirements	Page 6
6 Quality Assurance	Page 7
6.1 Qualifications	Page 7

SCOPE

This document contains details about the aspirating smoke detector **TITANUS *PRO-SENS*[®] /net TP-4-F**.

1 **TITANUS[®] Family – Introduction**

The **TITANUS[®]** family of aspirating smoke detectors is uniquely designed to provide consistent performance and protection levels in medium to high-sensitivity ASD applications. It covers a wide range of extreme applications without compromising high levels of sensitivity and performance. Consistent performance is possible because of a combination of sophisticated technologies being brought together:

High-Power Light Source (**HPLS**) technology, patented **LOGIC-SENS[®]** fire pattern recognition algorithms and a wide range of custom accessories ensure **TITANUS[®]** will maintain high levels of sensitivity and false alarm immunity even in challenging environments such as heavy industry and recycling plants.

Simplified installation and maintenance result in reduced overall costs throughout the entire system life cycle. For instance, special **TITANUS[®]** variants can be installed entirely within cold storage facilities at temperatures as low as -40 °C eliminating the need to compromise integrity of the thermally insulated room by piping through walls in order to install the detection unit in warmer areas.

PIPE-GUARD advanced air flow monitoring technology measures all system air flow not only through the entire pipe system but also through the detection chamber, sensing changes of as little as +/-10%. Consistent system architecture together with common installation and service protocols throughout the entire **TITANUS[®]** product line round out the **TITANUS[®]** integrated family concept, resulting in substantial benefits for distributors, installers and end users.

2 **TITANUS *PRO-SENS*[®] /net TP-4-F – General Information**

TITANUS *PRO-SENS*[®] /net is WAGNER's universal aspirating smoke detector. Its modular design facilitates cost-effective solutions for a wide range of specialized application requirements.

An optional second plug-in detector module allows one air sampling unit to economically monitor two separate areas or can alternatively be used for cross-zoning alarm verification (double knock).

TITANUS *PRO-SENS*[®] /net TP-4-F shows an operating temperature range from -40 °C to +60 °C and incorporates 2 alarm levels per detector module. Dry contacts for connection to any fire alarm control panel as well as free slots for bus modules and/or the optional TCP/IP network module and/or data logger from WAGNER are standard.

Area of coverage (system limit) is up to 3,000 m² per detector module. National regulations need to be considered.

3 Approvals

TITANUS *PRO-SENS*[®] /net TP-4-F shall be approved and/or listed by:

- FM (Factory Mutual), US*
- EAC (Eurasian Conformity), Eurasia
- IBS (Institut für Brandschutztechnik und Brandschutzforschung GmbH), Austria
- LPCB (Loss Prevention Certification Board), UK
- UL (Underwriters Laboratories Inc.), US*
- ULC (Underwriters Laboratories Canada), Canada*
- VdS Schadenverhütung GmbH, Germany

*) *approved version: TP-4-F-U*

4 Codes, Standards or Regulations

TITANUS *PRO-SENS*[®] /net TP-4-F shall comply with the following codes and standards regarding product conformity and/or installation:

- British Fire Protection Systems Association, Code of Practice for Category 1 Aspirating Detection Systems
- British Standards, BS 5839 Part 1 or BS 6266
- EN 50155 (Railway Standard)
- EN 54-20 (Classes A, B and C)
- FM 3230*
- ISO 7240-20 (Classes A, B and C)
- NFPA 76, US*
- NEC Standards, US*
- UL 268, 6th Edition*
- Local codes and standards

*) *fulfilled by version: TP-4-F-U*

5 System Description

5.1 General Requirements

1. The aspirating smoke detector shall incorporate latest LED sensor technology. Depending on the detection goal, sensors with appropriate sensitivity shall be used to provide very early smoke detection, early smoke detection or standard smoke detection according to EN 54-20 Classes A, B and C.
2. Plug-in detector modules of different base sensitivities shall be available for economically meeting the requirements according to the relevant EN 54-20 Class.
3. The aspirating smoke detector shall be able to be equipped with either one or two plug-in detector modules allowing to double the area of coverage or to perform cross-zoning alarm verification (double knock).
4. Appropriate external air filter technology and/or steam trap shall provide protection against dust, dirt and condensing humidity relating to the environmental conditions of the monitoring area. External air filter solution shall provide large surface for prolonged maintenance periods. The customer shall be able to change external filter media without assistance of installer and/or maintenance company. Filters must be approved according to EN 54-20.
5. Fire pattern recognition algorithms shall be implemented in order to enhance false alarm immunity and at the same time to maintain a high level of sensitivity even in challenging environments. This way, particles which due to their size cannot be separated by air filters nor be ignored by detection wavelength, shall be eliminated via their nuisance signature.
6. The aspirating smoke detector shall operate in a defined condition, without using features of automatic sensitivity reduction leading to an undefined signal-to-noise-ratio as this could compromise the detection goal and/or the level of safety.
7. State-of-the art algorithms for further enhancing false alarm immunity are a pre-requisite. Particularly drift compensation (relative alarm threshold) shall be incorporated as it is a well-proven technique in the field of fire detection for avoiding false alarms by keeping equal distance between background noise and alarm threshold under slowly changing environmental conditions.
8. Commissioning of the aspirating smoke detector shall not necessarily require PC or programming unit. The aspirating smoke detector shall be designed modularly for enabling fast and easy maintenance.
9. The aspirating smoke detector shall optionally be able to provide cross-zoning alarm verification (double knock) in order to trigger an automatic fire extinguishing/suppression system.
10. The aspirating smoke detector shall incorporate a display featuring a fault LED as well as LEDs for pre-alarm and main alarm per channel. In the case of cross-zoning alarm verification (double knock), a common alarm LED can be used for two channels.
11. The aspirating smoke detector shall be able to operate inside the cold storage area at a temperature as low as $-40\text{ }^{\circ}\text{C}$, rather than compromising the integrity of a thermally insulated room due to wall breakthrough for pipe run. The installation inside the cold storage area shall avoid well-known problems of condensation and icing of the air sampling pipework routed outside the cold storage area.
12. The aspirating smoke detector shall be connectable to up to 2 optional balanced or unbalanced 25 mm pipe systems.
13. Plastic clips with rubber inserts shall optionally be provided to allow de-icing by means of injection of compressed air into the pipe network.

5.2 Performance Requirements

The system:

- shall be able to be equipped with either one or two plug-in detector modules allowing to double the area of coverage or to perform cross-zoning alarm verification (double knock)
- shall be capable of providing up to 4 alarm levels per device
- shall provide 2 alarm LEDs per channel as well as LEDs for fault and operation at the front side
- shall have adjustable smoke sensitivity to match on-site detection requirements
- shall be capable of being equipped with detector modules having a pre-alarm sensitivity of up to 0.01% obs/m
- shall be tested and approved to support an air sampling pipe length of up to 300 m per detector module or 600 m per system
- shall be tested and approved to support up to 63 sampling points per detector module
- shall allow coverage of up to 3,000 m² per detector module as a system limit
- shall be approved to provide Class A, Class B and/or Class C sensitivity according to EN 54-20 and ISO 7240-20
- shall be capable of being equipped with an optional remote parallel display
- shall report fault, pre-alarm and main alarm messages by output relays
- shall report messages, smoke level and air flow data as plain text information via diagnostics tool and/or with optional network module via web server (TCP/IP) or SNMP
- shall provide technology which allows monitoring of the condition of the detection chamber
- shall provide the ability to sense changes of air flow as little as +/-10% for monitoring filter contamination and/or pipe blockage
- shall be capable of operating within a temperature range from -40 °C to +60 °C
- shall provide drift compensation in accordance with existing standards in order to maintain both high sensitivity and high immunity to false alarms in case of changing background conditions (caused, e.g., by dust)
- shall allow adjusting time delay for alarm and fault per area of coverage
- shall provide input for referencing to enhance false alarm immunity in case of external pollution

5.3 System Design Requirements

1. Computer-based design software shall provide calculations for detector settings and pipe planning showing high reliability of calculation in case of deviation between planning phase and factual realization. Such deviations can be caused, for example, by subsequently planned ceiling beams or installations that prevent the originally expected pipe run.
2. The usage of any pipe accessory which might compromise transport time and/or sensitivity (e.g. air filter) is only allowed if computer-based design software takes this influence into account and if the software is approved to do so.

5.4 Application Specific Requirements

1. An optional plug-in network module shall facilitate the integration of the detector into Ethernet TCP/IP networks. At a minimum, the following detector information shall be available via the network: Alarm status, fault status, fault specification, smoke density, condition of the detection chamber, air flow and settings.
2. For use in cold storage areas the following accessories shall be available: Plastic clips with rubber inserts for de-icing by means of air purging, automatic air purging system and appropriate accessories. The ASD shall be able to operate at temperatures as low as -40 °C. The ASD must be able to operate inside the cold storage area to avoid problems of condensation and/or icing that usually occur on the pipe routed to the outside and to avoid compromising the integrity of the thermally insulated room due to wall penetrations for the pipe routing.

6 Quality Assurance

6.1 Qualifications

1. Manufacturer

The manufacturer shall have at least 20 years of production experience in the manufacture and design of highly sensitive aspirating smoke detectors.

The manufacturer must be certified for production according to ISO 9001.

The manufacturer's production shall be audited by VdS and LPCB to ensure the highest production quality.

2. Technology

High-power LED light source technology shall be used.

The air flow through the detection chamber shall be monitored to avoid blockage and thereby blindness of the aspirating smoke detector without notice.

An algorithm shall facilitate to keep equal distance between background noise and alarm threshold under slowly changing environmental conditions in order to enhance false alarm immunity while at the same time ensuring stable fire detection properties.

If the aspirating smoke detector provides a learning tool for desensitization and if a test fire is agreed to be performed in order to verify detection quality, then the test fire shall be conducted after the learning phase has been completed. The automatically adjusted sensitivity shall be documented and checked for conformity with the relevant standards.

Fire pattern recognition shall be used to distinguish deception scenarios from fire scenarios with the greatest possible certainty.

WAGNER Group GmbH (Headquarter)

Schleswigstraße 1 – 5

30853 Langenhagen

Phone: +49. 511. 973 83-0

E-Mail: info@wagnergroup.com



You can find your personal

WAGNER contact at

www.wagnergroup.com

